

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
BUREAU OF CONSTRUCTION CODES  
BARRIER FREE DESIGN BOARD  
611 W. Ottawa Street, First Floor  
Lansing, MI 48933**

**Project No. 111452  
Grace Baptist Church of Romeo  
Use Group: A3**

**172 W. Lafayette  
Romeo, MI  
Macomb County**

**ORDER OF THE MICHIGAN BARRIER FREE DESIGN BOARD**

The Bureau of Construction Codes reviewed the submission dated March 21, 2016, and all supplemental submission for Grace Baptist Church of Romeo, City of Romeo. This order is issued pursuant to Section 5(6)(a) of 1966 P.A. 1, as amended; 1972 P.A. 230, as amended; and Section 81 of 1969 of P.A. 306, as amended, and Rule R 125.1016.

**FINDINGS AND CONCLUSIONS:** The compelling need is established based on the structural limitations.

THEREFORE, it is the order of the Bureau of Construction Codes, plan review division Executive order 1996-2, to grant a relief from the following sections:  
2009 ICC/ANSI A 117.1, Section 603.2.1 for the turning space.  
2009 ICC/ANSI A 117.1, Section 604.3 for the clearance for the water closet.

The Bureau of Construction Codes and the Board can only grant or deny exceptions to Michigan's barrier free design requirements. The Bureau of Construction Codes and the Board has no authority over the federal standards contained in the Americans with Disabilities Act of 1990, 42 U.S.C. 1224.



Stanley S. Skopek, RA  
Chief, Plan Review Division for the  
Barrier Free Design Board  
cc: Village of Romeo

April 26, 2016

**THE ORDER SHALL BE DISPLAYED IN A CONSPICUOUS LOCATION FOR  
PUBLIC EXAMINATION AS A CONDITION OF THE EXCEPTION.**